

FIRE SAFETY CERTIFICATE

No.

Dated:

Certified that the PINKZ PUBLIC SCHOOL (OBSE) name of the building or premises) at

No. 621, Arni-Polur Main Road, Kasthambadi, (address) comprised

of 1 basement(s) and G+2 (upper floors) owned/ occupied by PINKZ PUBLIC SCHOOL

(name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of

Fire Service on 24.01.2024 (date of inspection) in the presence of P.J. GENA BETSY, PRINCIPAL (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes

PRE KG TO XII (X/ XII) With effect from 24.01.2024 for a period of 24.01.2025 year in accordance with rule and subject to compliance of specific conditions as appended:-

1. —
2. —
3. —
4. —

Issued on 24.01.2024 (date of issue) at POLUR (place) by

*Strike out whichever is not applicable.

Signature with Seal:

Name

Designation

Name & Address of Department/ Office:

STATION OFFICER

FIRE & RESQUE STATION

POLUR-606 803, T.V. MALAI, DT

R. KARTHIKEYAN

STATION OFFICER

STATION OFFICER,
FIRE & RESQUE STATION.
POLUR-606 803. T.V. MALAI, DT

CORRESPONDENT
To **PINKZ PUBLIC SCHOOL**
621, Arni-Polur Main Road,
Kasthambadi - 606903,
Tiruvannamalai Dist, Tamil Nadu
(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf;

TAMILNADU FIRE AND RESCUE SERVICE DEPARTMENT.
FIRE AND RESCUE STATION, POLUR.

R.C.No:21/V/2024, Date:22.01.2024,
Sl.No. 01/2024.

Date: 24.01.2024.

NO OBJECTION CERTIFICATE

**Sub: Fire and Rescue Service Department–Fire and Rescue
Station– Polur – Issue of No Objection
Certificate – Functioning the School – Reg.**

**Ref: 1)G.O.No.122 School Education (2) Department,
Dt.14.09.2004.**

**2)G.O.No.123 School Education (2) Department,
Dt.14.09.2004.**

**3)Application Received from PRINCIPAL. PINKZ PUBLIC SCHOOL,
KASATHAMBADI VILLAGE, POLUR TALUK, THIRUVANNAMALAI DISTRICT,
Dated:22.01.2024.**

<<<<<<<<<<<>>>>>>>>>

Based on the reference in the G.Os cited 1&2,
Mr.R.KARTHIKEYAN, Station Officer , **POLUR** inspected the school in the name of
“PINKZ PUBLIC SCHOOL” situated at S.F.No: 620/1B1 ,620/5A, 620/5B, 620/5C2,
621/1A, 621/2A, 621/2B, 622/1, Arni to Polur road, Kasthambadi , Polur Taluk,
Thiruvannamalai District, on **24.01.2024** Considering on Fire and Rescue view there is
No Objection for functioning the School in the above mentioned address.

TERMS & CONDITIONS.

- 1) As per the National Building Code of India 2016, Tariff advisory Committee, ISI and other Government Rule regarding Safety, School Building had to be equipped with all safety equipments in good condition and ready to utilize anytime and any where in the School premises.
- 2) As per G.O.Ms.No. 713 Sub (Protection – 17) dated 17.08.2005 School has to give training regarding Fire Safety & Rescue to the person handling first aid & safety.
- 3) Sufficient Fire Safety equipments should be provided and maintained in the premises.
- 4) For the maintenance of Fire Safety Equipments School has to appoint a Fireman or a trained team in Fire Safety Equipments.
- 5) Institution has to conduct mock drill with the association of Fire & Rescue Department in order about the Fire protections & Rescue among the employers in the institution.
- 6) This Certificate valid upto one year from the date of issue

Office Seal:



[Signature]
24/01/2024
STATION OFFICER,
FIRE & RESCUE STATION,
POLUR-606803, T.V.MALAI DT.,

To:
THE CORRESPONDENT.PINKZ PUBLIC SCHOOL,
ARANI TO POLUR ROAD,
KASTHAMBADI VILLAGE, POLUR TALUK,
THIRUVANNAMALAI DISTRICT – 606 903.

Copy to: District Officer, Thiruvannamalai,